



August 15, 2012

Proper Cleaning of Gas Chlorination Components

To ensure the longevity of your Hydro Instruments product(s) we recommend that they be routinely checked for cleaning and replacement of worn or damaged parts.

When servicing your Hydro Instruments gas chlorination equipment you may find it necessary to clean parts due to chemical precipitants or accumulation of some other foreign matter. When this circumstance presents itself please follow these guidelines to make sure those parts do not become damaged or disfigured:

1. Only use mild solvents such as: Soap & Water, Aqueous acid or Isopropyl alcohol.

NOTE: Never use harsh chemicals that can attack the material it's being used on. For example: Do not use acetone or cleaning agents containing acetone on plastic or rubber.

2. Use a soft, nonabrasive cloth to wipe away the accumulation of debris or chemical build up. This is especially true for parts that require a smooth surface to seal properly (i.e. the inlet valve stem or rate adjustment valve).
3. Make sure to only use new O-rings and gaskets when putting the product back together. Worn or compromised seals can be a hazard.

IMPORTANT: SOME CLEANING AGENTS MAY BE DANGEROUS IF MIXED TOGETHER OR MAY HAVE A REACTION WITH THE CHEMICAL THE PRODUCT IS USED TO FEED. ALWAYS MAKE SURE THAT PARTS ARE COMPLETELY CLEAN AND DRY BEFORE REASSEMBLY AND PUTTING THE PRODUCT BACK INTO USE.