



# GAS CHLORINATION SYSTEM 502 BASIC

100 PPD (2 kg/hr)

March 2001

No pressurized chlorine manifold required  
Chlorinators should be directly mounted to chlorine cylinders

